

Date: 13 /04/2022

To,  
The Fire Officer,  
State Fire Prevention Services,  
Bhuj – Nagarpalika,  
Bhuj - Kutch.

-: Declaration Regarding Fire Protection System :-

We, hereby declare that our **School Building / Educational Building (ACADEMIC HEIGHTS PUBLIC SCHOOL)** is address:**Survey no 248 Village Shinay, Gandhidham - Kutch.**

We, hereby declare that our building height is **8.10 Mtrs App.** Which is not above **09 meters**, so fire NOC is not required as per URBAN DEVELOPMENT AND URBAN HOUSING DEPARTMENT Notification No.:GH/V/9 of 2021/AGN-102021 – 100 – L 1 Dated 22 January, 2021. But for the safety purpose we have strictly followed the requirement of NATIONAL BUILDING CODE OF INDIA FOR FIRE AND SAFETY. We have provided in our building fire protection system as under which as per requirement of NATIONAL BUILDING CODE OF INDIA PART FOR FIRE AND SAFETY.

- |  |         |
|--|---------|
| 1. Fire Hydrant Line (100mm – 4") connected to 05 HP Motor : | 01 Nos. |
| 2. Fire Hose Reel Wall Mounted (25mm x 30mtrs) :             | 02 Nos. |
| 3. ABC / DCP Type 02 / 05 / 06 Kgs Fire Extinguisher :       | 05 Nos. |



આ યોગ્ય ઉદ્ધેશના બંધી કરી  
તા. 12/04/2022 સુધી માન્ય રહેશે

Admin officer  
The School Management Committee (SMC)  
Academic Heights Public School (Shinay)

  
Authorised Signatory