

Date: 18 /05/2023

To,
The Fire Officer,
State Fire Prevention Services,
Bhuj – Nagarpalika,
Bhuj - Kutch.

-: Declaration Regarding Fire Protection System :-

We, hereby declare that our **School Building / Educational Building ACADEMIC HEIGHTS PUBLIC SCHOOL** is address : Survey No 248 Village Shinay, Gandhidham- Kutch


We, hereby declare that our building height is **8.10 Mtrs App.** Which is not above **09 meters** , so fire NOC is not required as per URBAN DEVELOPMENT AND URBAN HOUSING DEPARTMENT Notification No.:GH/V/9 of 2021/AGN-102021 – 100 – L 1 Dated 22 January, 2021. But for the safety purpose we have strictly followed the requirement of NATIONAL BUILDING CODE OF INDIA FOR FIRE AND SAFETY. We have provided in our building fire protection system as under which as per requirement of NATIONAL BUILDING CODE OF INDIA PART FOR FIRE AND SAFETY.

- | | | |
|--|---|---------|
| 1. Fire Hydrant Line (100mm – 4") connected to 05 HP Motor | : | 01 Nos. |
| 2. Fire Hose Reel Wall Mounted (25mm x 30mtrs) | : | 02 Nos. |
| 3. ABC / DCP Type 02 / 05 / 06 Kgs Fire Extinguisher | : | 10 Nos. |



બીજી ઓફિસરને જાણવા માટે
11/2/23 11/2/23 11/2/23
18 MAY 2024

ACADEMIC HEIGHTS PUBLIC SCHOOL
MANAGED BY SANSKRITI ADUPIR KUTCHM


Harsh N. Lalwani